
CERTIFICATE OF APPROVAL

No CF 635

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

PYROPLEX LIMITED

The Furlong, Droitwich, Worcestershire WR9 9BG
Tel: 01905 795 432 Fax: 01905 791 878
www.pyroplex.com

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

200 & 400 Series Pyroplex
Pipe Collars & Pipe Wraps

TECHNICAL SCHEDULE

TS03 Penetration Sealing
Systems

Signed and sealed for and on behalf of CERTIFIRE

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Paul Duggan
Certification Manager

Issued: 24th September 2008
Reissued: 7th September 2018
Valid to: 6th September 2023



CERTIFICATE No CF 635

PYROPLEX LIMITED

PYROPLEX 200 & 400 SERIES PIPE COLLARS & WRAPS

1. This approval relates to the use of Pyroplex 200 & 400 Series pipe closure devices for fire protection where there are services penetrating walls and floors. The detailed scope is given in the Approval Matrix included in this Certificate. This shows the acceptable devices/configurations to provide fire resistance periods in accordance with BS EN 1366-3 of up to 240 minutes for differing services and elements of construction.
2. This certification is provided to the client for its own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. This certification will set out our conclusion as to whether the information provided is sufficient to demonstrate compliance with the relevant standard. We cannot, and will not, opine upon whether Building Control will regard the certification as sufficient for any purpose. In accepting our quote you agree to us providing you with the certification without any guarantee as to whether it will be accepted by Building Control or any other authority as evidence of compliance with the Building Regulations or other relevant standards.
4. The product is approved on the basis of:
 - i) Initial type testing
 - ii) Audit testing at the frequency specified in TS03
 - iii) A design appraisal against TS03
 - iv) Inspection and surveillance of factory production control
 - v) Production surveillance under ISO 9001:2008
5. The masonry or concrete walls shall be at least 150 mm thick and have at least the same fire rating as that required for the penetration seal.
6. The services which may be fitted through the seals are PVC pipes, as detailed within the Approval Matrix included in this Certificate.
7. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No CF 635 PYROPLEX LIMITED

PYROPLEX 200 SERIES COLLARS

Approval Matrix - Up To 120 Minute Walls & Floors

Product Name:	Pyroplex 200 Series Pipe Collars – PPC55 2 – PPC160-2			
PVC Pipe Size	Pyroplex Product References	Wall/ Floor Thickness	Integrity	Insulation
55 mm Ø by 3.2 mm wall thickness	PPC55-2	150 mm	120 minutes	120 minutes
82 mm Ø by 3.2 mm wall thickness	PPC82-2			
110 mm Ø by 3.2 mm wall thickness	PPC110-2			
160 mm Ø by 3.2 mm wall thickness	PPC160-2			
Walls & Floors	<p>The walls and floors shall be a minimum of 150 mm thick. The minimum density for the concrete or brick of the wall is 780kg/m³ and for walls & floors made of concrete blocks/concrete is 600kg/m³. All concrete or masonry shall have at least the same fire rating as that required for the pipe collar</p>			
Application Technique:	<p>Concrete/masonry walls & floors: The collar wrapped around the pipe, clipped closed and screw fixed to the soffit of the floor or to both faces of wall constructions.</p>			
Service Coat-Back :	Not required	U Value:	Not known	
Service Support Requirements:	Services should be rigidly supported via steel angles, hangars or channels, not further than 320 mm and 500 mm from the surface of the sealing system on both faces.			
Resistance to Smoke:	Not evaluated by this approval	Weather Capability:	Not evaluated by this approval	
Acoustic Rating:	Not evaluated by this approval	Movement Capability:	Not evaluated by this approval	

CERTIFICATE No CF 635 PYROPLEX LIMITED

PYROPLEX 200 SERIES PIPE WRAPS

Approval Matrix - Up To 120 Minute Walls & Floors

Product Name:	Pyroplex 200 Series Pipe Wraps – PPW55-2 – PPW160-2				
PVC Pipe Size	Pyroplex Product References	Aperture Size	Wall/ Floor Thickness	Integrity	Insulation
55 mm Ø by 3.2 mm wall thickness	PPW55-2	67 mm Ø	150 mm	120 minutes	120 minutes
82 mm Ø by 3.2 mm wall thickness	PPW82-2	94 mm Ø			
110 mm Ø by 3.2 mm wall thickness	PPW110-2	125 mm Ø			
160 mm Ø by 3.2 mm wall thickness	PPW160-2	190 mm Ø			
Walls & Floors	<p>The walls and floors shall be a minimum of 150 mm thick. The minimum density for the concrete or brick of the wall is 780kg/m³ and for walls & floors made of concrete blocks/concrete is 600kg/m³. All concrete or masonry shall have at least the same fire rating as that required for the pipe wrap.</p>				
Application Technique:	<p>Concrete/masonry walls & floors: The wrap shall be inserted into the oversize aperture around the pipe, approximately 5 mm from the exposed surface of the wall/soffit of the floor. The remaining unfilled aperture is then infilled with a sand/cement mortar mix.</p>				
Service Coat-Back :	Not required		U Value:	Not known	
Service Support Requirements:	Services should be rigidly supported via steel angles, hangars or channels, not further than 320 mm and 500 mm from the surface of the sealing system on both faces.				
Resistance to Smoke:	Not evaluated by this approval		Weather Capability:	Not evaluated by this approval	
Acoustic Rating:	Not evaluated by this approval		Movement Capability:	Not evaluated by this approval	

CERTIFICATE No CF 635 PYROPLEX LIMITED

PYROPLEX 400 SERIES COLLARS

Approval Matrix - Up To 180 Minute Walls & Floors

Product Name:	Pyroplex 400 Series Pipe Collars – PPC25-4 – PPC250-4			
PVC Pipe Size	Pyroplex Product References	Wall/ Floor Thickness	Integrity	Insulation
25 mm Ø by 1.8 mm wall thickness	PPC25-4	150 mm	180 minutes	180 minutes
32 mm Ø by 1.8 mm wall thickness	PPC32-4			
40 mm Ø by 1.8 mm wall thickness	PPC40-4			
48 mm Ø by 3.2 mm wall thickness	PPC48-4			
55 mm Ø by 3.2 mm wall thickness	PPC55-4			
68 mm Ø by 3.2 mm wall thickness	PPC55-4			
82 mm Ø by 3.2 mm wall thickness	PPC82-4			
110 mm Ø by 3.2 mm wall thickness	PPC110-4			
125 mm Ø by 3.2 mm wall thickness	PPC125-4			
135 mm Ø by 3.2 mm wall thickness	PPC135-4			
160 mm Ø by 3.2 mm wall thickness	PPC160-4			
200 mm Ø by 5.4 mm wall thickness	PPC200-4			
225 mm Ø by 7.2 mm wall thickness	PPC225-4			
250 mm Ø by 7.2 mm wall thickness	PPC250-4			
Walls & Floors	<p>The walls and floors shall be a minimum of 150 mm thick. The minimum density for the concrete or brick of the wall is 780kg/m³ and for walls & floors made of concrete blocks/concrete is 600kg/m³. All concrete or masonry shall have at least the same fire rating as that required for the pipe collar</p>			
Application Technique:	<p>Concrete/masonry walls & floors: The collar is wrapped around the pipe, clipped closed and screw fixed to the soffit of the floor or to both faces of wall constructions.</p>			
Service Coat-Back :	Not required	U Value:	Not known	
Service Support Requirements:	Services should be rigidly supported via steel angles, hangars or channels, not further than 320 mm and 500 mm from the surface of the sealing system on both faces.			
Resistance to Smoke:	Not evaluated by this approval	Weather Capability:	Not evaluated by this approval	
Acoustic Rating:	Not evaluated by this approval	Movement Capability:	Not evaluated by this approval	

CERTIFICATE No CF 635 PYROPLEX LIMITED

PYROPLEX 400 SERIES COLLARS

Approval Matrix - Up To 240 Minute Walls

Product Name:		Pyroplex 400 Series Pipe Collars – PPC200-4 – PPC400-4			
PVC Pipe Size	Pyroplex Product References	Wall Thickness	Integrity	Insulation	
200 mm Ø by 5.4 mm wall thickness	PPC200-4	150 mm	240 minutes	240 minutes	
225 mm Ø by 7.2 mm wall thickness	PPC225-4				
250 mm Ø by 7.2 mm wall thickness	PPC250-4		180 minutes	180 minutes	
315 mm Ø by 8.2 mm wall thickness	PPC315-4				
350 mm Ø by 9.8 mm wall thickness	PPC350-4		120 minutes	120 minutes	
400 mm Ø by 9.8 mm wall thickness	PPC400-4				
HDPE Pipe Size	Pyroplex Product References	Wall/ Floor Thickness	Integrity	Insulation	
350 mm Ø by 23.7 mm wall thickness	PPC350-4	150 mm	60 minutes	60 minutes	
400 mm Ø by 23.7 mm wall thickness	PPC400-4				
Walls	<p>The walls shall be a minimum of 150 mm thick. The minimum density for the concrete or brick of the wall is 780kg/m³ and for walls made of concrete blocks/concrete is 600kg/m³. All concrete or masonry shall have at least the same fire rating as that required for the seal.</p>				
Application Technique:	<p>Concrete/masonry walls: The collar is wrapped around the pipe, clipped closed and screw fixed to both faces of wall constructions.</p>				
Service Coat-Back :	Not required		U Value:	Not known	
Service Support Requirements:	Services should be rigidly supported via steel angles, hangars or channels, not further than 320 mm and 500 mm from the surface of the sealing system on both faces.				
Resistance to Smoke:	Not evaluated by this approval		Weather Capability:	Not evaluated by this approval	
Acoustic Rating:	Not evaluated by this approval		Movement Capability:	Not evaluated by this approval	

CERTIFICATE No CF 635 PYROPLEX LIMITED

PYROPLEX 400 SERIES COLLARS

Approval Matrix - Up To 180 Minute Floors

Product Name:	Pyroplex 400 Series Pipe Collars – PPC315-4 – PPC400-4			
PVC Pipe Size	Pyroplex Product References	Floor Thickness	Integrity	Insulation
315 mm Ø by 8.2 mm wall thickness	PPC315-4	150 mm	120 minutes	120 minutes
350 mm Ø by 9.8 mm wall thickness	PPC350-4*		180 minutes	180 minutes
400 mm Ø by 9.8 mm wall thickness	PPC350-4*			
HDPE Pipe Size	Pyroplex Product References	Wall/ Floor Thickness	Integrity	Insulation
350 mm Ø by 23.7 mm wall thickness	PPC350-4	150 mm	60 minutes	60 minutes
400 mm Ø by 23.7 mm wall thickness	PPC400-4			
* Collar fitted to both sides of the floor				
Floors	The floors shall be a minimum of 150 mm thick. The minimum density for the floors made of concrete blocks/concrete is 600kg/m ³ . All concrete or masonry shall have at least the same fire rating as that required for the pipe collar			
Application Technique:	Concrete/masonry floors: The collar is wrapped around the pipe, clipped closed and screw fixed to the soffit of the floor unless specified otherwise above.			
Service Coat-Back :	Not required	U Value:	Not known	
Service Support Requirements:	Services should be rigidly supported via steel angles, hangars or channels, not further than 320 mm and 500 mm from the surface of the sealing system on both faces.			
Resistance to Smoke:	Not evaluated by this approval	Weather Capability:	Not evaluated by this approval	
Acoustic Rating:	Not evaluated by this approval	Movement Capability:	Not evaluated by this approval	

CERTIFICATE No CF 635 PYROPLEX LIMITED

PYROPLEX 400 SERIES PIPE WRAPS

Approval Matrix - Up To 180 Minute Walls

Product Name:	Pyroplex 400 Series Pipe Wraps – PPW55 – PPW160-4				
PVC Pipe Size	Pyroplex Product References	Aperture Size	Wall Thickness	Integrity	Insulation
55 mm Ø by 3.2 mm wall thickness	PPW55-4	67 mm Ø	150 mm	180 minutes	180 minutes
82 mm Ø by 3.2 mm wall thickness	PPW82-4	94 mm Ø			
110 mm Ø by 3.2 mm wall thickness	PPW110-4	125 mm Ø		120 minutes	120 minutes
125 mm Ø by 3.2 mm wall thickness	PPW125-4	155 mm Ø			
160 mm Ø by 3.2 mm wall thickness	PPW160-4	190 mm Ø			
Walls & Floors	<p>The walls shall be a minimum of 150 mm thick. The minimum density for the concrete or brick of the wall is 780kg/m³ and for walls made of concrete blocks/concrete is 600kg/m³. All concrete or masonry shall have at least the same fire rating as that required for the Pipe collar</p>				
Application Technique:	<p>Concrete/masonry walls: The wrap shall be inserted into the oversize aperture around the pipe, approximately 5 mm from the exposed surface of the wall. The remaining unfilled aperture is then infilled with a sand/cement mortar mix.</p>				
Service Coat-Back :	Not required		U Value:	Not known	
Service Support Requirements:	Services should be rigidly supported via steel angles, hangars or channels, not further than 320 mm and 500 mm from the surface of the sealing system on both faces.				
Resistance to Smoke:	Not evaluated by this approval		Weather Capability:	Not evaluated by this approval	
Acoustic Rating:	Not evaluated by this approval		Movement Capability:	Not evaluated by this approval	

CERTIFICATE No CF 635 PYROPLEX LIMITED

PYROPLEX 400 SERIES PIPE WRAPS

Approval Matrix - Up To 180 Minute Floors

Product Name:	Pyroplex 400 Series Pipe Wraps – PPW55 – PPW160-4				
PVC Pipe Size	Pyroplex Product References	Aperture Size	Wall/ Floor Thickness	Integrity	Insulation
55 mm Ø by 3.2 mm wall thickness	PPW55-4	67 mm Ø	150 mm	120 minutes	120 minutes
82 mm Ø by 3.2 mm wall thickness	PPW82-4	94 mm Ø			
110 mm Ø by 3.2 mm wall thickness	PPW110-4	125 mm Ø			
125 mm Ø by 3.2 mm wall thickness	PPW125-4	155 mm Ø		180 minutes	180 minutes
160 mm Ø by 3.2 mm wall thickness	PPW160-4	190 mm Ø			
Walls & Floors	The floors shall be a minimum of 150 mm thick. The minimum density for floors made of concrete blocks/concrete is 600kg/m ³ . All concrete or masonry shall have at least the same fire rating as that required for the seal.				
Application Technique:	Concrete/masonry floors: The wrap shall be inserted into the oversize aperture around the pipe, approximately 5 mm from the exposed surface of the soffit of the floor. The remaining unfilled aperture is then infilled with a sand/cement mortar mix.				
Service Coat-Back :	Not required		U Value:	Not known	
Service Support Requirements:	Services should be rigidly supported via steel angles, hangars or channels, not further than 320 mm and 500 mm from the surface of the sealing system on both faces.				
Resistance to Smoke:	Not evaluated by this approval		Weather Capability:	Not evaluated by this approval	
Acoustic Rating:	Not evaluated by this approval		Movement Capability:	Not evaluated by this approval	