

TEST REPORT SPREADSHEET

Certification No.		CFR1603041	CFR1604131	WF372576	CFR1703211	CFR1603081	WF513890	CFR1608261	CFR1608251	UKTC-002909	UKTC-002909	CFR1711211	CFR1703171	CFR1603241	CFR1605191	CFR1604211	CFR1604281	CFR1604291	CFR1707121	CFR1707121	UKTC-004633	UKTC-000909	UKTC-001311	UKTC-000709	UKTC-001009	UKTC-002310	UKTC-001209	UKTC-001109	UKTC-002909	UKTC-002909	
Test Standard		EN1634pt1	EN1634pt1	EN1634pt1	BS476 pt22	EN1634pt1	BS476 pt22	EN1634pt1	EN1634pt1	EN1634pt1	EN1634pt1	EN1634pt1	BS476 pt22	EN1634pt1	EN1634pt1	EN1634pt1	BS476 pt22	BS476 pt22	EN1634pt1	EN1634pt1	EN1634pt1	BS476 pt22	BS476 pt22	BS476 pt22	BS476 pt22	BS476 pt22	EN1634pt1	EN1634pt1	BS476 pt22	BS476 pt23	BS476 pt23
Gaps		7mm	25mm	30mm	25mm	7mm	3mm	30mm	24mm	30mm	30mm	39mm	30mm	25mm	10mm	25mm	25mm	28mm	30mm	32mm	15mm	12mm	15mm	20mm	12mm	15mm	10mm	20mm	30mm	30mm	
FD30		X	X			X	X			X		X	X	X				X	X		X	X	X		X	X	X	X		X	
FD60				X	X			X	X		X				X	X	X			X				X					X		
Frames Width	66																						X								
	70						X			X											X									X	
	80				X						X		X									X			X	X	X	X	X		
	100	X	X	X		X		X	X			X		X	X	X	X	X	X	X				X							
Frame Material	MDF	X	X		X	X						X	X									X				X	X	X			
	Softwood						X			X				X				X			X		X			X				X	
	Hardwood			X				X	X		X				X	X													X		
Wall Construction	Timber Stud				X		X						X				X	X													
	Steel Stud	X	X	X		X		X	X	X	X			X	X	X			X	X	X	X		X	X	X	X	X	X	X	
	Block Work											X											X								