

DECLARATION OF PERFORMANCE

According to Annex III of Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

QUELFIRE QSS – ACRYLIC SEALANT

1. Unique identification code of the product-type:

Quelfire QSS Acrylic Sealant

2. Type, batch or serial number as required pursuant to Article 11(4):

See batch number displayed on the product

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification:

Fire stopping and sealing product for penetration seals, see ETA 17/0788

Cable penetrations	Insulated & non insulated, cables, cable trays & cable ladders	The field of application has to comply with the content of the related ETA 17/0788
Pipe penetrations	Insulated & non insulated metal pipes	The field of application has to comply with the content of the related ETA 17/0788

4. Name, registered trade name or registered trade mark and contact address as required pursuant to Article 11(5): Quelfire

Ltd, Unit 3, Millbuck Way, Springvale Industrial Estate, Sandbach, Cheshire, CW11 3HT,

Tel: 0161 928 7308, Email: sales@quelfire.co.uk

5. Authorised representative: n.a.

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: System 1

7. Harmonised standard: n.a.

8. In the case of the declaration of performance concerning product covered by a Harmonised Standard and/or ETA:

Warrington Certification Ltd issued ETA Number 17/0788 on the basis of Guideline for European Technical Approval of Fire Stopping and Fire Sealing Products: ETAG 026 Part 1: "General" and Part 2: "Penetration Seals" performed initial and continuous surveillance of the place of manufacture and the factory production control implemented, sampled product and witnessed initial type testing under system 1 and issued the Certificate of Constancy of Performance 1121-CPR-JA5116

9. Declared performance:


Essential Characteristic	Declared performance/Harmonised technical specification
Reaction to fire	Class F according to EN 13501-1
Resistance to fire	Resistance to fire performance and field application in accordance with EN 13501-2 see ETA 17/0788
Air Permeability	Tested in accordance with EN 1026, see ETA 17/0788
Dangerous substances	See ETA 17/0788 – Declaration – compliant
Airbourne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1, see ETA 17/0788
Durability and serviceability	Z ¹ (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA Technical Report – TR024
Movement Capability	According to ISO 11600 : ISO 11600 – F – 12.5p.
Other	Not applicable/No performance determined

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer.



Keith Wells
Managing Director
Quelfire Ltd



Darryl Wells
Product Development
Quelfire Ltd