

## DECLARATION OF PERFORMANCE

According to Annex III of Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

### QUELFIRE QSS – ACRYLIC SEALANT

- Unique identification code of the product-type:**  
Quelfire QSS Acrylic Sealant
- Type, batch or serial number as required pursuant to Article 11(4):**  
See batch number displayed on the product
- Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification:**  
Fire stopping and sealing product for linear joint & gap seals, see ETA 17/0789


|                          |                                                                                                                                      |                                                                                           |
|--------------------------|--------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------|
| Linear Joint & Gap Seals | Horizontal & vertical linear joints in flexible wall constructions                                                                   | <b>The field of application has to comply with the content of the related ETA 17/0789</b> |
| Linear Joint & Gap Seals | Horizontal & vertical linear joints in rigid wall constructions, rigid floor constructions, steel constructions & wood constructions | <b>The field of application has to comply with the content of the related ETA 17/0789</b> |

- Name, registered trade name or registered trade mark and contact address as required pursuant to Article 11(5):** Quelfire Ltd, Unit 3, Millbuck Way, Springvale Industrial Estate, Sandbach, Cheshire, CW11 3HT, Tel: 0161 928 7308, Email: [sales@quelfire.co.uk](mailto:sales@quelfire.co.uk)
- Authorised representative:** n.a.
- System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:** System 1
- Harmonised standard:** n.a.
- In the case of the declaration of performance concerning product covered by a Harmonised Standard and/or ETA:**  
Warrington Certification Ltd issued ETA Number 17/0789 on the basis of Guideline for European Technical Approval of Fire Stopping and Fire Sealing Products: ETAG 026 Part 1: "General" and Part 2: "Penetration Seals" performed initial and continuous surveillance of the place of manufacture and the factory production control implemented, sampled product and witnessed initial type testing under system 1 and issued the Certificate of Constancy of Performance 1121-CPR-JA5116
- Declared performance:**


| Essential Characteristic             | Declared performance/Harmonised technical specification                                                                                    |
|--------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Reaction to fire</b>              | Class F according to EN 13501-1                                                                                                            |
| <b>Resistance to fire</b>            | Resistance to fire performance and field application in accordance with EN 13501-2 see ETA 17/0789                                         |
| <b>Air Permeability</b>              | Tested in accordance with EN 1026, see ETA 17/0789                                                                                         |
| <b>Dangerous substances</b>          | See ETA 17/0789 – Declaration – compliant                                                                                                  |
| <b>Airbourne Sound Insulation</b>    | Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1, see ETA 17/0789                                               |
| <b>Durability and serviceability</b> | Z <sup>1</sup> (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA Technical Report – TR024 |
| <b>Movement Capability</b>           | According to ISO 11600 : ISO 11600 – F – 12.5p.                                                                                            |
| <b>Other</b>                         | Not applicable/No performance determined                                                                                                   |

- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.**

Signed for and on behalf of the manufacturer.



Keith Wells  
Managing Director  
Quelfire Ltd



Darryl Wells  
Product Development  
Quelfire Ltd