certifire

CERTIFICATE OF APPROVAL
No CF 392

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ASSA ABLOY LTD

School Street, Willenhall, WV13 3PW, United Kingdom
Telephone: 01543 460030

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT	TECHNICAL SCHEDULE
Exidor 200/300 Series and 500 Series (Slimline) Emergency Exit Devices	**TS31 The Contribution of Emergency Exit Devices to the Fire Resistance of Door Assemblies**

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 19th November 2004
Reissued: 22nd October 2026
Valid to: 18th November 2031

warringtonfire certifire CERTIFICATION

certifire UKAS PRODUCT CERTIFICATION 0087

This certificate is the property of Warringtonfire Testing and Certification Limited
Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF392
ASSA ABLOY LTD

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.

2. This approval relates to the following items:

Reference	Description
Exidor 200/300 Series	
293	Push Pad Bolt
293SD	Push Pad Bolt – Steel door fixing
293A	Push Pad Bolt – Adjustable shoots
293A/SD	Push Pad Bolt – Steel door fixing/ Adjustable shoots
310	Push Pad Single Panic Bolt with Vertical Pullman Latches
310SD	Push Pad Single Panic Bolt with Vertical Pullman Latches – Steel door fixing
297	Push Pad Panic Latch
297SD	Push Pad Panic Latch – Steel door fixing
306SD	Push Pad Mortice Actuator with Cylinder Mortice Night Latch – Steel door fixing
307	Push Pad Single Panic Bolt with Horizontal Pullman Latches
307SD	Push Pad Single Panic Bolt with Horizontal Pullman Latches – Steel door fixing
Exidor 500 Series (Slimline)	
501-P	Push Pad Emergency Exit Latch
502A-P	Push Pad Emergency Exit Bolt
503A-P	Push Pad Three Point Emergency Exit Bolt
512-P	Push Pad Emergency Exit Bolt With Vertical Latches
513-P	Push Pad Three Point Emergency Exit Bolt With Vertical Latches
522-P	Push Pad Emergency Exit Bolt With Horizontal Latches
523-P	Push Pad Three Point Emergency Exit Bolt With Horizontal Latches

3. This approval relates to the use of the family of exit devices with the following door assemblies:

Previously proven unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber or cellulosic cores, in timber frames having a fire resistance up to 120 minutes* (Code ITT).

Previously proven unlatched door assemblies consisting of predominantly steel leaves in steel frames, insulated or uninsulated for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM)

Previously proven unlatched intumescent sealed door assemblies consisting of timber faced and edged leaves with timber or cellulosic cores in fully-insulated steel frames having a fire resistance up to 120 minutes* (Code ITM)

* Excludes the 306SD emergency exit mortice actuator with cylinder mortice nightlatch.

This certificate is the property of Warringtonfire Testing and Certification Limited
Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF392
ASSA ABLOY LTD

4. The exit devices are approved on the basis of:

   i) Initial type testing to EN 179 for mechanical properties
   ii) Initial type testing to EN 1634-1 for the fire resistance performance of doorsets
   iii) An appraisal against TS31
   iv) Certification of quality management system.
   v) Inspection and surveillance of factory production control
   vi) On-going audit testing in accordance with EN 179:2008

5. This approval is applicable only to the specified Exidor exit devices and relevant accessories when used with door assemblies that are CERTIFIRE approved or have achieved the appropriate fire resistance performance when tested at a laboratory accredited to IS/IEC 17025 (under International Laboratory accreditation Cooperation (ILAC) membership), in accordance with BS 476: Part 22: 1987 and/or BS EN 1634:1). Failure to install the device and accessories in the appropriate manner will invalidate this certificate of approval.

6. The centre modules shall not be fitted higher than 1100 mm from the handle spindle to the finished floor level of the surrounding floors.

7. The purpose of the appraisal is only to consider the influence of fitting the proposed hardware items to a doorset, and not its ability to provide an essential latching action; it is therefore a requirement of this certificate that the doorsets to which the panic hardware is fitted shall have been previously tested unlatched in the configuration required.

8. The spindle hole through the door shall be a maximum of 16 mm diameter unless the doorset has test evidence that proves spindle holes of a greater size than this.

9. Recessing for cylinder mortice nightlatch shall result in a tight fit without voids.

10. Cylinders shall only be fitted to MM/IMM doors which have previously been shown capable of accommodating the installation of cylinder locks without detriment to the doorset's performance.

11. The mortice locks may incorporate Euro profile cylinders as follows:

    i) Single cylinder
    ii) Double cylinder
    iii) Cylinder and thumbturn
    iv) Steel cylinders only

    Note: The hole in the door face shall follow the shape of the cylinders and be as tight as possible; furthermore the single cylinders door preparation will penetrate through only half the thickness of the door leaf)

12. It is assumed that single-acting doorsets will be fitted with a CE marked surface mounted closing device which is capable of fully closing the doorset from any position and overcoming any latch mechanism. It is further assumed that the doorsets will be in the fully closed position.

This certificate is the property of Warringtonfire Testing and Certification Limited
Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF392
ASSA ABLOY LTD

13. All door hardware is subject to the acceptance by the chosen door assembly supplier's tested, assessed or certificated scope, which generally identifies the types of hardware approved, the required specification/design based on the key materials/ maximum size (e.g. spindle hole, Outside Access Device aperture in face, etc.), and the application of any additional intumescent protection.

    On this basis approval should be sought from the specific door assembly supplier to ensure compliance based on this assessed/certificated scope.

14. The approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

This certificate is the property of Warringtonfire Testing and Certification Limited
Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF392
ASSA ABLOY LTD

15. The following tables show acceptable doorsets types and fire resistance periods:

	Approved Door Type			
Class	**IMM**	**MM**	**ITT**	**ITM**
BS476-22				
FD20	✓	✓	✓*	✓*
FD30	✓	✓	✓*	✓*
FD60	✓	✓	✓*	✓*
FD90	✓	✓	✓*	✓*
FD120	✓	✓	✓*	✓*
FD240	✓	✓	✘	✘
EN1634-1				
Integrity only	**IMM**	**MM**	**ITT**	**ITM**
20	✓	✓	✓*	✓*
30	✓	✓	✓*	✓*
60	✓	✓	✓*	✓*
90	✓	✓	✓*	✓*
120	✓	✓	✓*	✓*
240	✓	✓	✘	✘
Integrity/insulation	**IMM**	**MM**	**ITT**	**ITM**
20	✓	✓	✓*	✓*
30	✓	✓	✓*	✓*
60	✓	✓	✓*	✓*
90	✓	✓	✓*	✓*
120	✓	✓	✓*	✓*
240	✓	✓	✘	✘

Key:

✓ - approved

✘ - Not approved

✓* Excludes the 306SD emergency exit mortice actuator with cylinder mortice nightlatch.

This certificate is the property of Warringtonfire Testing and Certification Limited
Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

16. Doors are categorised as the following types:

Code ITT - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

Code ITM - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in steel frames.

Code MM - 20 to 240 minute door assemblies consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 to 240 minute door assemblies consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

Scope of Approval:

- The panic hardware may not be fitted to timber doorsets without perimeter intumescent fire seals within the frame rebate or edge of the door leaf.

- The following associated external access devices may be installed onto 30 or 60 minute ITT timber doorsets, and IMM and MM uninsulated and insulated steel based door leaves for up to 240 minute performances:

200/300 Series	306 Series
298 (knob)	302EA (knob)
302EA (knob)	302EC (knob)
302EC (knob)	302OA (knob)
302OA (knob)	302OC (knob)
302OC (knob)	322EA (lever)
322EA (lever)	322EC (lever)
322EC (lever)	

- The following 'Universal' external access devices may be installed onto 30 or 60 minute ITT timber doorsets, and IMM and MM uninsulated and insulated steel based door leaves for up to 240 minute performances:

200/300 SERIES	
325EC Silver	Lever OAD Euro W/Lock 200 Series OAD
325EA Silver	Lever OAD Euro W/Out Lock 200 Series OAD
326EC Silver	Knob Operated OAD Euro W/Lock 200 Series OAD
326EA Silver	Knob Operated OAD Euro Nolock 200 Series OAD

This certificate is the property of Warringtonfire Testing and Certification Limited
Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF392
ASSA ABLOY LTD

500 SERIES	
525EC Silver	Lever OAD Euro W/Lock 500 Series OAD
525EA Silver	Lever OAD Euro W/Out Lock 500 Series OAD
526EC Silver	Knob Operated OAD Euro W/Lock 500 Series OAD
526EA Silver	Knob Operated OAD Euro Nolock 500 Series OAD

- The door leaves for ITT timber based doorsets for 30 or 60 minute performances shall have a minimum leaf thickness of 44 mm and 54 mm, for 30 and 60 minute doorsets respectively.

- The door leaves for IMM and MM steel based doorsets for up to 240 minute performances shall have a minimum leaf thickness 45 mm.

Classification codes

The approval provides the following classifications:

Exidor 200/300 Series

3	7	6	B	1	3	4	2	B	A

Exidor 500 Series (Slimline)

3	7	6	B	1	3	2	2	B	A

Further Information

Further information regarding the details contained in this data sheet may be obtained from Assa Abloy Ltd (Tel: 01543 578661).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

This certificate is the property of Warringtonfire Testing and Certification Limited
Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436