



CERTIFICATE OF APPROVAL

No CF 849

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

Unit B, Dukes Drive, Kingmoor Park North,
Carlisle, Cumbria CA6 4SH, United Kingdom
Tel: 01228 672900 Fax: 01228 672928

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Zoo Hardware Ltd Stainless Steel
Ball Bearing Hinges & Lift-Off
Hinges

TECHNICAL SCHEDULE

TS24 The Contribution of
Single Axis Hinges to the Fire
Resistance of Door Assemblies

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 20th July 2011
Reissued: 26th May 2026
Valid to: 27th June 2031



EWC-QU-FT-733 (Issue 3)

Page 1 of 10



CERTIFICATE No CF 849

ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

- 1) This certification is provided to the client for their own purposes, and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 2) This approval relates to the following Zoo Hardware Ltd stainless steel, single axis hinges:

Ball Bearing hinges approved for ITT 20, 30, 60, 90 and 120 minutes and MM/IMM up top 240 minutes	
Reference	Description
ZHSS243P	Grade 13 Stainless Steel - 102 x 76 x 3mm
ZHSS243P3	Grade 13 Stainless Steel - 102 x 76 x 3mm (pair and a half)
ZHSS243PVD	Grade 13 Stainless Steel - 102 x 76 x 3mm
ZHSS243PVD3	Grade 13 Stainless Steel - 102 x 76 x 3mm (pair and a half)
ZHSS243RP	Grade 13 Stainless Steel Radius - 102 x 76 x 3mm Radius
ZHSS243RPVD	Grade 13 Stainless Steel Radius 102 x 76 x 3mm Radius
ZHSS243RS	Grade 13 Stainless Steel Radius - 102 x 76 x 3mm
ZHSS243S	Grade 13 Stainless Steel - 102 x 76 x 3mm
ZHSS243S3	Grade 13 Stainless Steel - 102 x 76 x 3mm (pair and a half)
ZHSS243SPCB	Grade 13 Stainless Steel - 102 x 76 x 3mm
ZHSS43P	Grade 13 Stainless Steel - 102 x 76 x 3mm
ZHSS43RP	Grade 13 Stainless Steel Radius 102 x 76 x 3mm
ZHSS43RS	Grade 13 Stainless Steel Radius 102 x 76 x 3mm
ZHSS43S	Grade 13 Stainless Steel - 102 x 76 x 3mm
ZHSSDB243S	Grade 13 Stainless Steel Dog Bolt Door Hinge 102 x 76 x 3mm
ZHSS7667	Grade 11 Stainless Steel - 76 x 67 x 2.5mm

Ball Bearing hinges approved for ITT 60, 90 and 120 only and MM/IMM up top 240 minutes	
Reference	Description
ZHSS244S	Grade 13 Stainless Steel - 102 x 102 x 3mm
ZHSS244P	Grade 13 Stainless Steel - 102 x 102 x 3mm
ZHSS244PVD	Grade 13 Stainless Steel - 102 x 102 x 3mm

Lift-Off hinges approved for ITT 20, 30 and 60 minutes only	
Reference	Description
VLH243-13	Grade 13 Stainless Steel - 102 x 76 x 3mm

The hinges are available in 201, 304 or 316 grade stainless steel, and with square or radiused corners.

- 3) This approval relates to the use of the above single axis hinges in contributing to the fire resistance performance of timber-based doorsets and steel based doorsets, as defined in BS EN 1634-1 or BS 476: Part 22: 1987.



CERTIFICATE No CF 849

ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

4) This approval relates to their use with the following door assemblies:-

Ball bearing hinges* - Code ITT - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

** ZHSS244 hinges are not approved for use with 20 or 30 minute ITT doorsets.*

Ball bearing hinges - Code MM/IMM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Lift-off hinges - Code ITT - 20 minute to 60 minute door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

5) The hinges are approved on the basis of:


- i) Initial type testing to EN1935 and EN 1634-1
- ii) An appraisal against TS24
- iii) Certification of quality management system.
- iv) Inspection and surveillance of factory production control
- v) Ongoing audit testing in accordance with TS24 requirements

6) The door assembly shall be a CERTIFIRE approved product or have achieved the appropriate fire resistance performance when tested at a laboratory accredited to UKAS or IS/IEC 17025 (under International Laboratory accreditation Cooperation (ILAC) membership), in accordance with BS 476: Part 22: 1987 and/or BS EN 1634:1 with hinges of a similar size.

7) The hinges should only be used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987), the critical aspects of the doorset construction are considered to be the material of the door frame, the leaf to frame clearance gaps and the lipping material. Attention should be paid to these details and these should not be amended from that previously fire tested. The following minimum specification shall be followed, unless the chosen doorset has evidence to the contrary with hinges of a similar size/specification:

a. 20, 30 and 60 minute timber-based assemblies (ITT):

- i) Door frame minimum density - 450 kg/m³ (20 & 30 minutes), 640 kg/m³ (60 minutes)
- ii) Door leaves shall have a minimum thickness of 44 mm for 20 & 30 minute applications and 54 mm for 60 minute applications.
- iii) Lipping minimum density - 640 kg/m³.

EWC-QU-FT-733 (Issue 3)
Signed 
CXE96273-20

Page 3 of 10

Issued: 20th July 2011
Reissued: 26th May 2026
Valid to: 27th June 2031

CERTIFICATE No CF 849

ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

- b. Steel-based assemblies (MM/IMM)
- i) Door leaves shall have a minimum thickness of 44 mm for up to 240 minute applications.
 - ii) Excludes lift-off hinges.
- 8) For 90 minute and 120 minute timber-based assemblies (ITT), Zoo hinges shall only be fitted to doorsets which have previously been tested with hinges of a similar size, subject to the following requirements:
- i) The required intumescent protection shall be as tested by the chosen door manufacturer. In all cases this shall be a minimum of a 2 mm thick mono ammonium phosphate or graphite-based intumescent sheet material incorporated beneath each hinge blade, however, this protection shall be increased as required based on the chosen doorset manufacturers test data.
 - ii) Where the perimeter intumescent fire seal tested within the chosen doorset bypasses the hinge, this detail shall be maintained.
 - iii) The critical dimensions of the Zoo hinge to be used shall be based on the size of the hinge tested originally by the chosen doorset manufacturer, with the following tolerance:

Hinge Specification of Chosen Doorset	
Component/dimension	Tolerance/Rule
Hinge blade	
Width	+0/-5% of tested hinge
Height	+/-20% of tested hinge
Thickness	+/-15% of tested hinge
Knuckle	
Diameter	Minimum 14 mm
Fixings	
Quantity	Maximum 3No. fixings tested
Size	4.7 mm dia. Minimum
Length	No shorter than that tested
Position (width)	+/-10% from the positions of the fixings in the tested hinge when measured with respect to the centre lines of the blade

Note:

- i. *Where the Zoo hinge does not comply with the parameters identified above it shall not be used in conjunction with the chosen 90 minute and 120 minute timber-based assemblies (ITT).*
- ii. *Lift-off hinges are not approved for use with ITT 90 and 120 minute doorsets.*



CERTIFICATE No CF 849

ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

9) When fitted to insulated timber-based door assemblies, the required additional intumescent protection will be as follows:

i) The required protection for 30 minute ITT applications will be:

a. 1 mm thickness of mono ammonium phosphate or graphite-based intumescent material (see 'Scope of Approval' below) behind both blades.

Or

b. 0.8 mm thick FlexiFire graphite-based intumescent material behind both blades.*

ii) The required protection for 60 minute ITT applications will be:

a. 2 mm thickness of mono ammonium phosphate or graphite-based intumescent material (see 'Scope of Approval' below) behind both blades.

Or

b. 0.8 mm thick FlexiFire graphite-based intumescent material behind both blades*

iii) For 60 minute ITT applications only, where 0.8 mm thick FlexiFire graphite-based intumescent material is used 15 mm of perimeter intumescent fire seal within the edge of the door or frame rebate is required to by-pass the hinges.

**Excludes ZHSS244S, ZHSS244P and ZHSS244PVD hinges*


iv) The required intumescent protection for 90 and 120 minute ITT applications shall be as tested by the chosen door manufacturer. In all cases this shall be a minimum of a 2 mm thick mono ammonium phosphate or graphite-based intumescent sheet material (see 'Scope of Approval' below) incorporated beneath each hinge blade, however, this protection shall be increased as required based on the chosen doorset manufacturers test data.

7. The hinges may only be fitted in the manner described in this certificate and subject to any limitations on the inclusion of hinges specified for the door leaf. This approval is applicable only to the specified hinges used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and when using appropriate intumescent protection.

8. Recessing for hinges shall result in a tight fit, allowing for any intumescent protection where required.

9. Hinges shall only be fitted using the fixings supplied by the hinge manufacturer. Regard should be paid to the maximum door mass permitted to be used with the hinge (see classifications).

10. The ITT doorsets shall be installed in accordance with BS 8214.

EWC-QU-FT-733 (Issue 3)
Signed 
CXE96273-20

Page 5 of 10

Issued: 20th July 2011
Reissued: 26th May 2026
Valid to: 27th June 2031



CERTIFICATE No CF 849
ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

11. All door hardware is subject to the acceptance by the chosen door assembly supplier's tested, assessed or certificated scope, which generally identifies the types of hardware approved, the required specification/design based on the key materials/ maximum size (e.g. flap size, knuckle diameter, fixing specification, etc.), and the application of any additional intumescent protection.

On this basis approval should be sought from the specific door assembly supplier to ensure compliance based on this assessed/certificated scope

12. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

EWC-QU-FT-733 (Issue 3)
Signed
CXE96273-20

Page 6 of 10

Issued: 20th July 2011
Reissued: 26th May 2026
Valid to: 27th June 2031



CERTIFICATE No CF 849
ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

13. The following table show acceptable doorset types and fire resistance periods for the ball bearing hinges:

Class	Approved Door Type			
	IMM	MM	ITT	ITM
BS476-22				
FD20	✓	✓	✓*	✗
FD30	✓	✓	✓*	✗
FD60	✓	✓	✓*	✗
FD90	✓	✓	✓*	✗
FD120	✓	✓	✓*	✗
FD240	✓	✓	✗	✗
EN1634-1				
Integrity only	IMM	MM	ITT	ITM
20	✓	✓	✓*	✗
30	✓	✓	✓*	✗
60	✓	✓	✓*	✗
90	✓	✓	✓*	✗
120	✓	✓	✓*	✗
240	✓	✓	✗	✗
Integrity/insulation	IMM	MM	ITT	ITM
20	✓	✓	✓*	✗
30	✓	✓	✓*	✗
60	✓	✓	✓*	✗
90	✓	✓	✓*	✗
120	✓	✓	✓*	✗
240	✓	✓	✗	✗

Key:

- ✓ - approved
- ✗ - Not approved
- ✓* - ZHSS244 hinges are not approved for use with 20 or 30 minute ITT doorsets

EWC-QU-FT-733 (Issue 3)

Signed

CXE96273-20

Page 7 of 10

Issued: 20th July 2011

Reissued: 26th May 2026

Valid to: 27th June 2031




CERTIFICATE No CF 849
ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

14. The following table show acceptable doorset types and fire resistance periods for the Lift-off hinges:

15.	Approved Door Type			
Class	IMM	MM	ITT	ITM
BS476-22				
FD20	x	x	✓	x
FD30	x	x	✓	x
FD60	x	x	✓	x
FD90	x	x	x	x
FD120	x	x	x	x
FD240	x	x	x	x
EN1634-1				
Integrity only	IMM	MM	ITT	ITM
20	x	x	✓	x
30	x	x	✓	x
60	x	x	✓	x
90	x	x	x	x
120	x	x	x	x
240	x	x	x	x
Integrity/insulation	IMM	MM	ITT	ITM
20	x	x	✓	x
30	x	x	✓	x
60	x	x	✓	x
90	x	x	x	x
120	x	x	x	x
240	x	x	x	x

Key:

- ✓ - approved
- x - Not approved

EWC-QU-FT-733 (Issue 3)
Signed 
CXE96273-20

Page 8 of 10

Issued: 20th July 2011
Reissued: 26th May 2026
Valid to: 27th June 2031



CERTIFICATE No CF 849

ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

16. Doors are categorised as the following types:

Code ITT - 20 minute to 120 minute doorsets containing intumescent seals and intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

Code ITM - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in steel frames.

Code MM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

Scope of Approval:

- The hinges may not be fitted to timber doorsets without perimeter intumescent fire seals within the frame rebate or edge of the door leaf.
- ZHSS244 hinges are not approved for use with 20 or 30 minute ITT doorsets.
- The VLH243-13 lift-off hinges are approved for use on ITT doorsets of up to 60 minutes performance only.
- Where graphite based intumescent sheet material is to be used in lieu of the mono ammonium phosphate tested, the proposed graphite-based intumescent sheet material, shall have suitable test evidence in the required thickness or less, with timber-based doorset of the required classification period, in with steel hinges of a minimum size of 100 mm x 75 mm.
- As identified in Annex E of EN1935, where doors incorporate closers without backcheck the effective door mass should assumed to be 20% higher than the actual door mass. For back-check closers the effective door mass should assumed to be 75 % higher than the actual door mass.

EWC-QU-FT-733 (Issue 3)

Signed
CXE96273-20

Page 9 of 10

Issued: 20th July 2011

Reissued: 26th May 2026

Valid to: 27th June 2031



CERTIFICATE No CF 849

ERA HOME SECURITY LTD T/A ZOO HARDWARE LTD

Classification codes

The above approval provides the following classifications:

All hinge models except ZHSSDB243S, ZHSS7667 and VLH243-13:

4	7	6	1	1	4	0	13
---	---	---	---	---	---	---	----

ZHSSDB243S - Stainless Steel Dog Bolt Hinge 102 mm x 76 mm x 3 mm:

4	7	6	1	1	4	1	13
---	---	---	---	---	---	---	----

ZHSS7667- Stainless Steel Hinge 76 x 67 x 2.5mm:

3	7	4	1	1	4	0	11
---	---	---	---	---	---	---	----


VLH243-13 lift-off hinges:

4	7	6	1	1	4	0	13
---	---	---	---	---	---	---	----

Further Information

Further information regarding the details contained in this certificate may be obtained from ERA Home Security Ltd T/A Zoo Hardware Ltd (Tel: 01228 672900).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

EWC-QU-FT-733 (Issue 3)
Signed 
CXE96273-20

Page 10 of 10

Issued: 20th July 2011
Reissued: 26th May 2026
Valid to: 27th June 2031