

# UL-EU CERTIFICATE

**Certificate No.**  
UL-EU-01022-EN

**Issue date**  
2016-05-27

**Issue No.**  
5

**Re-Issue date**  
2026-05-01

**Expiry date**  
2036-04-30



4705

**This is to acknowledge that:**  
FSi Limited

**Address:**  
Westminster Industrial Estate  
Tamworth Road  
Measham  
DE12 7DS  
United Kingdom

**Has had the product:**  
PipeBloc PWP

evaluated and meets the requirements of the standards:

EAD 350454-00-1104 / EN 13501-2 / EN 13501-1

**Places of production:**  
A/008 & X/001

Authorised Signatory:

A handwritten signature in blue ink, appearing to read 'Chris Johnson'.

Chris Johnson  
Issued by UL International (UK) Ltd

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



## Appendix UL-EU CERTIFICATE UL-EU-01022-EN

This certificate relates to the use of PipeBloc PWP for fire stopping where services penetrate floors and walls. The detailed scope is given in pages 3 to 16 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 240 minutes (EI 240).

The product is certificated on the basis of:

- i) Inspection and surveillance of factory production control by UL
- ii) Fire resistance test data in accordance with EN 1366-3: 2009.
- iii) Classification in accordance with EN 13501-2
- iv) Classification in accordance with EN 13501-1
- ii) Durability and Serviceability as defined in EAD 350454-00-1104

The durability class of PipeBloc PWP is X - intended for use in conditions exposed to weathering (includes all lower classes).

According to EN 1366-3: 2021+A1: 2024, Clause H.4.1.8.6.2, the following end uses are envisaged\* based upon the tested pipe end configuration:

| Pipe material | Tested pipe end | Envisaged use scenario   |
|---------------|-----------------|--|
| Metal         | C/U or C/C      | Closed pipe systems (e.g. systems under pressure)                          |
|               | U/U, U/C or C/U | Ventilated pipe systems (e.g. sewage pipes) and for closed pipe systems    |
| Plastic       | U/U or C/U      | Ventilated pipe systems and for closed pipe systems                        |
|               | U/U             | Ventilated pipe systems, for rainwater systems and for closed pipe systems |

\* In the case where a national prescription is in conflict with the content of the table above, the national prescriptions prevail.



# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

| Product-type: Pipe Wrap  |  | Intended use: Penetration Seal                           |  |
|--|--|--|--|
| Assessment method  | Essential characteristic                                 | Product Performance                                      |  |
| <b>BWR 2 Safety in case of fire</b>  |  |  |  |
| EN 13501-1   | Reaction to fire   | Class E  |  |
| EN 13501-2   | Resistance to fire                                       | See pages 4 - 16   |  |
| <b>BWR 3 Hygiene, health and environment</b>   |  |  |  |
| EN 1026  | Air permeability   | No performance determined                                |  |
| EAD 350454-00-1104,<br>Annex C   | Water permeability                                       | No performance determined                                |  |
| Declaration of manufacturer & EN 16516   | Content, emission and/or release of dangerous substances | Use categories: IA1, S/W2<br>Declaration of manufacturer |  |
| Declaration of manufacturer & EN 16516   | Content, emission and/or release of dangerous substances | Declaration of manufacturer                              |  |
| <b>BWR 4 Safety in use</b>   |  |  |  |
| EOTA TR 001:2003   | Mechanical resistance and stability                      | No performance determined                                |  |
| EOTA TR 001:2003   | Resistance to impact/movement                            | No performance determined                                |  |
| EOTA TR 001:2003   | Adhesion   | No performance determined                                |  |
| EAD 350454-00-1104,<br>Clause 2.2.9  | Durability   | X  |  |
| <b>BWR 5 Protection against noise</b>  |  |  |  |
| EN 10140-1,2,4,5/ EN ISO 717-1   | Airborne sound insulation                                | No performance determined                                |  |
| <b>BWR 6 Energy economy and heat retention</b>   |  |  |  |
| EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456 | Thermal properties                                       | No performance determined                                |  |
| EN ISO 12572, EN 12086, EN ISO 10456   | Water vapour permeability                                | No performance determined                                |  |




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

## Floors

### Rigid Floors Minimum Thickness 150 mm

#### Plastic pipes

| Rigid Floors ≥150 mm  |                                |  |   |  |
|---|--------------------------------|--|---|--|
|  |                                |  |   | <b>Key</b><br>1. Plastic Pipe<br>2. Rigid floor<br>3. Pipebloc PWP<br>4. Pyrocoustic Sealant |
| Penetration Service   | Annular Space (mm)             | Distances (mm)                         | Installation  | Classification   |
| PVC-U, PVC-C <sup>(1)</sup> – See 3.1.1, Graph 1 for scope                        | ≤ 10 depending on product size | Edge – 10<br>Penetration Service ≥ 100 | Pipebloc PWP fit into topside and underside of the floor recessed by 5mm. Pyrocoustic Sealant applied to topside and underside of the floor sealing in the wrap | EI 120 U/C, C/C  |
| PVC-U, PVC-C <sup>(1)</sup> – See 3.1.2, Graph 2 for scope                        |                                |  |   | EI 60 U/C, C/C   |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.1.5, Graph 5 for scope                    |                                |  |   | EI 120 U/C, C/C  |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.1.6, Graph 6 for scope                    |                                |  |   | EI 120 U/C, C/C  |
| PP <sup>(3)</sup> – See 3.1.3, Graph 3 for scope                                  |                                |  |   | EI 120 U/C, C/C  |
| PP <sup>(3)</sup> – See 3.1.4, Graph 4 for scope                                  |                                |  |   | EI 15 U/C, C/C   |

All services supported with pipe supports at 400 mm from the upper face of the floor.

<sup>(1)</sup> PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1 and PVC-C according to EN 1566-1


<sup>(2)</sup> PE pipe according to EN 1519-1, EN 12201-2 and EN 12006-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1

<sup>(3)</sup> PP pipe according to EN 1852-1: 2009

# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

## Plastic pipes in Stopseal Batt

Rigid Floors  $\geq 150$  mm



### Key

1. Plastic Pipe
2. Rigid floor
3. Pipebloc PWP
4. Stopseal Batt
5. Pyrocoustic Sealant

| Penetration Service  | Opening Size (mm)       | Distances (mm)                                | Installation   | Classification        |
|--|-------------------------|---|--|-----------------------|
| PVC-U, PVC-C <sup>(1)</sup> – See 3.1.1, Graph 1 for scope     | $\leq 1500 \times 1100$ | Edge $\geq 0$<br>Penetration Service $\geq 0$ | Pipebloc PWP fit into topside and underside of the floor recessed by 5mm. Friction fit Stopseal Batt into aperture around Pipebloc PWP.<br>Pyrocoustic Sealant applied to topside and underside of the floor sealing in the wrap | <b>EI 60 U/C, C/C</b> |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.1.5, Graph 5 for scope |                         |   |  |                       |
| PP <sup>(3)</sup> – See 3.1.3, Graph 3 for scope               |                         |   |  |                       |

All services supported with pipe supports at 400 mm from the upper face of the floor.

(1) PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1 and PVC-C according to EN 1566-1

(2) PE pipe according to EN 1519-1, EN 12201-2 and EN 12006-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1

(3) PP pipe according to EN 1852-1: 2009



**Solutions**


Form-ULID-006104 V10.0

# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

## Rigid Floors Minimum Thickness 100 mm

### Plastic pipes in Stopseal Batt

Rigid Floors  $\geq 100$  mm



#### Key

1. Plastic Pipe
2. Rigid floor
3. Pipebloc PWP
4. Stopseal Batt
5. Pyrocoustic Sealant

| Penetration Service  | Opening Size (mm)       | Distances (mm)                                  | Installation  | Classification        |
|--|-------------------------|---|---|-----------------------|
| PVC-U, PVC-C <sup>(1)</sup> – See 3.1.1, Graph 1 for scope     | $\leq 1300 \times 1100$ | Edge – $\geq 0$<br>Penetration Service $\geq 0$ | Pipebloc PWP fit into topside and underside of the floor recessed by 5mm. Pattress fit Stopseal Batt on to aperture around Pipebloc PWP.<br>Pyrocoustic Sealant applied to topside and underside of the floor sealing in the wrap | <b>EI 60 U/C, C/C</b> |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.1.5, Graph 5 for scope |                         |   |   |                       |
| PP <sup>(3)</sup> – See 3.1.3, Graph 3 for scope               |                         |   |   |                       |

All services supported with pipe supports at 400 mm from the upper face of the floor.

<sup>(1)</sup> PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1 and PVC-C according to EN 1566-1

<sup>(2)</sup> PE pipe according to EN 1519-1, EN 12201-2 and EN 12006-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1

<sup>(3)</sup> PP pipe according to EN 1852-1: 2009




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

## Walls

Flexible or Rigid Walls Minimum Thickness 100 mm

### Plastic pipes

Flexible or rigid walls  $\geq 100$  mm



#### Key

1. Plastic Pipe
2. Flexible Wall
3. Pipebloc PWP
4. Pyrocoustic Sealant

| Penetration Service   | Opening Size (mm)                         | Distances (mm)                 | Installation   | Classification                  |
|---|---|--------------------------------|--|---------------------------------|
| PVC-U, PVC-C <sup>(1)</sup> – See 3.2.1, Graph 7 for scope      | As required by dimensions of Pipebloc PWP | Penetration Service $\geq 100$ | Pipebloc PWP fit into both sides of the wall recessed by 5 mm. Pyrocoustic Sealant applied to each face of the wall sealing in the wrap. | EI 90 U/C, C/C                  |
| PP <sup>(3)</sup> – See 3.2.2, Graph 8 for scope                |   |                                |  | EI 120 U/C, C/C                 |
| PP <sup>(3)</sup> – See 3.2.3, Graph 9 for scope                |   |                                |  | EI 90 U/C, C/C                  |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.2.4, Graph 10 for scope |   |                                |  | E 120 U/C, C/C, EI 90, U/C, C/C |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.2.5, Graph 11 for scope |   |                                |  | EI 90 U/C, C/C                  |

All services supported with pipe supports at 400 mm from both faces of the wall.

<sup>(1)</sup> PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1 and PVC-C according to EN 1566-1

<sup>(2)</sup> PE pipe according to EN 1519-1, EN 12201-2 and EN 12006-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1

<sup>(3)</sup> PP pipe according to EN 1852-1: 2009




**Solutions**

Form-ULID-006104 V10.0

# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

## Plastic pipes in Stopseal Batt

Flexible or Rigid Walls  $\geq 100$  mm insulated or uninsulated, lined, or unlined



### Key

1. Plastic Pipe
2. Flexible Wall
3. Stopseal Batt
4. Pipebloc PWP

| Penetration Service   | Opening Size (mm)      | Distances (mm)                                   | Installation  | Classification        |
|---|------------------------|--|---|-----------------------|
| PVC-U, PVC-C <sup>(1)</sup> – See 3.2.1, Graph 7 for scope      | $\leq 1200 \times 750$ | Edge – $\geq 50$<br>Penetration Service $\geq 0$ | Pipebloc PWP fit into both sides of the wall recessed by 5mm. Stopseal Batt pattress fit using Pyrocoustic Sealant between joints. Fixed to the substrate using 6 x 80 steel screws and steel washers, 100 mm overlap onto substrate. | <b>EI 60 U/C, C/C</b> |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.2.5, Graph 11 for scope |                        |  |   |                       |
| PP <sup>(3)</sup> – See 3.2.3, Graph 9 for scope                |                        |  |   |                       |

All services supported with pipe supports at 400 mm from both faces of the wall.

<sup>(1)</sup> PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1 and PVC-C according to EN 1566-1

<sup>(2)</sup> PE pipe according to EN 1519-1, EN 12201-2 and EN 12006-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1

<sup>(3)</sup> PP pipe according to EN 1852-1: 2009




**Solutions**

Form-ULID-006104 V10.0

# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

Flexible or Rigid Walls  $\geq 100$  mm insulated, unlined, or lined



### Key

1. Plastic Pipe
2. Flexible Wall
3. Stopseal Batt
4. Pipebloc PWP

| Penetration Service   | Opening Size (mm)       | Distances (mm)                             | Installation  | Classification        |  |                       |
|---|-------------------------|--|---|-----------------------|--|-----------------------|
| PVC-U, PVC-C <sup>(1)</sup> – See 3.2.6, Graph 12 for scope     | $\leq 1200 \times 730$  | Edge – 100<br>Penetration Service $\geq 0$ | Pipebloc PWP fit into both sides of the wall recessed by 5mm. Two 50 mm back-to-back Stopseal Batt friction fit using Pyrocoustic Sealant between joints. | <b>EI 90 U/C, C/C</b> |  |                       |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.2.4, Graph 10 for scope |                         |  |   |                       |  |                       |
| PP <sup>(3)</sup> – See 3.2.2, Graph 8 for scope                |                         |  |   |                       |  |                       |
| PVC-U, PVC-C <sup>(1)</sup> – See 3.2.6, Graph 8 for scope      | $\leq 2600 \times 2600$ |  |   |                       |  | <b>EI 60 U/C, C/C</b> |
| PE, ABS, SAN-PVC <sup>(2)</sup> – See 3.2.4, Graph 10 for scope |                         |  |   |                       |  |                       |
| PP <sup>(3)</sup> – See 3.2.2, Graph 8 for scope                |                         |  |   |                       |  |                       |

All services supported with pipe supports at 400 mm from both faces of the wall.

<sup>(1)</sup> PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1 and PVC-C according to EN 1566-1

<sup>(2)</sup> PE pipe according to EN 1519-1, EN 12201-2 and EN 12006-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1

<sup>(3)</sup> PP pipe according to EN 1852-1: 2009




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN


## Scope and Usage

### Floor

#### Graph 1




#### Graph 2




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

**Graph 3**




**Graph 4**




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

Graph 5




Graph 6




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

## Wall

### Graph 7




### Graph 8




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

**Graph 9**




**Graph 10**




# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

Graph 11



Graph 12



# Appendix UL-EU CERTIFICATE UL-EU-01022-EN

## Pipebloc PWP Usage

Ensure penetration service has been tested, tables are for usage guidance only.

| Pipebloc PWP Applied both sides of wall/floor |                       |
|---|-----------------------|
| <i>For use with plastic pipes</i>             |                       |
| Pipe Ø (mm)                                   | Layers of Pipebloc EL |
| 40  | 2                     |
| 55  | 2                     |
| 63  | 2                     |
| 75  | 2                     |
| 82  | 2                     |
| 90  | 3                     |
| 110   | 3                     |
| 125   | 4                     |
| 140   | 4                     |
| 160   | 4                     |
| 200   | 5                     |

| Single Pipebloc PWP Applied in floor |                       |
|--------------------------------------|-----------------------|
| <i>For use with plastic pipes</i>    |                       |
| Pipe Ø (mm)                          | Layers of Pipebloc EL |
| 40                                   | 4                     |
| 55                                   | 4                     |
| 63                                   | 4                     |
| 75                                   | 4                     |
| 82                                   | 4                     |
| 90                                   | 6                     |
| 110                                  | 6                     |
| 125                                  | 8                     |
| 140                                  | 8                     |
| 160                                  | 8                     |
| 200                                  | 10                    |



## Appendix UL-EU CERTIFICATE UL-EU-01022-EN

The UL-EU Marks, displayed below represent the enhanced and alternate version of the product marking. Either Mark can be used. These Marks shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



\*Note: E12345 is an example of the UL file number.

The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number and UL File number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

### PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at [www.ul.com](http://www.ul.com).

